

Catherine Dorau

12/28 Greg Porcello +4
WD, BB, KB, GN, MM
Robin Pearson
D. Bahata

From: Bob Proctor
Sent: Wednesday, December 27, 2017 1:46 PM
To: Catherine Dorau
Cc: Todd Dumais; Brittany Bermingham; Aimee Krauss; Tim Mikloiche
Subject: 54 Sunset Farm Rd. - File #1069, IWWA - (REGULATED ACTIVITY) -Site Plan for Savin
Residence received 12-22-17

Cathy,

The site plan (revision), LEI Project 17-383 received on 12-22-17, prepared for 54 Sunset Farm Rd. (File #1069) has been reviewed and the plan has been found to be essentially acceptable as presented. Site soil testing and evaluations have been completed for the proposed subsurface sewage disposal system and it has been demonstrated that a compliant system can be installed.

The size of the septic is designed for the four (4) bedroom home and any minor adjustments will be made at the time of installation. Select fill will be required as specified in the site plan, drawing # C-2, job # 1-383, as listed under the "Select Fill" portion of the plan. The leaching field location shall be staked out prior to installation and an engineered as-built provided for plan compliance.

Bob Proctor, RS
West Hartford-Bloomfield Health District
12-27-17